

U-VALUE CALCULATOR REPORT

Property Reference	21124	Issued on Date	20/12/2021
Assessment Reference		Prop Type Ref	u-values
Project	Re-Purposed PIR Insulation		
Calculation Type	Conversion (As Designed)		

SAP Rating		DER		TER	
Environmental		% DER<TER			
CO ₂ Emissions (t/year)		DFEE		TFEE	
General Requirements Compliance		% DFEE<TFEE			

Assessor Details	Mrs. Susan Fox, SF Energy Limited, Tel: 07825 631518, suzi@sfenergy.co.uk	Assessor ID	C358-0001
Client	MAC Architects, M151		

Building Elements

Wall Cedral Clad Wall column A - 120mm + 50mm Repurposed PIR

Wall Type: Standard Wall

U-VALUE CALCULATOR REPORT

Layer	Description	Thickness (mm)	Conductivity (W/m ² K)	Resistance (m ² K/W)	Fraction (%)
Ext surface				0.2900	
Layer 1	Cedral Cladding				
	Main construction	12	0.2120	0.0000	100.00
Layer 2	horizontal battens				
	Main construction	38	0.0000	0.0000	87.50
	Main construction	38	0.1300	0.0000	12.50
	Corrections - Cavity Ventilated, Emissivity: Low Emissivity (BR443)				
Layer 3	vertical battens				
	Main construction	25	0.0000	0.0000	91.67
	Main construction	25	0.1300	0.0000	8.33
	Corrections - Cavity Ventilated, Emissivity: Low Emissivity (BR443)				
Layer 4	Proctor Frameshield 100				
	Main construction	0.5	0.0000	0.0000	100.00
Layer 5	Orientated Strand Board				
	Main construction	9	0.1300	0.0692	100.00
Layer 6	KR Cladding Repurposed PIR / studs				
	Main construction	120	0.0310	3.8710	85.00
	Main construction	120	0.1300	0.9231	15.00
	Corrections - Air Gap: Level 1, Fasteners: None or plastic				
Layer 7	airspace / studs				
	Main construction	25	0.2273	0.1100	85.00
	Main construction	25	0.1300	0.1923	15.00
	Corrections - Cavity Unventilated, Emissivity: Normal				
Layer 8	KR Cladding Repurposed PIR				
	Main construction	50	0.0310	1.6129	100.00
	Corrections - Air Gap: Level 0, Fasteners: None or plastic				
Layer 9	Reflectatherm				
	Main construction	0.5	0.0000	0.0000	100.00
Layer 10	service void				
	Main construction	35	0.0449	0.7800	92.17
	Main construction	35	0.1300	0.2692	7.83
	Corrections - Cavity Unventilated, Emissivity: Normal				
Layer 11	Plasterboard, standard				
	Main construction	12.5	0.2100	0.0595	100.00
Int surface				0.1300	

Total resistance: **Upper limit =** 6.196 m² K/W **Lower limit =** 5.576 m² K/W **Average =** 5.886 m² K/W
Total correction = 0.0020 m² K/W **U-value (unrounded) =** 0.17 W/m² K

Unheated space: None

Total thickness: 328 mm

U-value: 0.17 W/m² K

Kappa: n/a